उत्तर प्रदेश में जल संसाधन संबंधित परियोजनाएं

3237. **चौधरी हरमोहन सिंह** : क्या जल संसाधन मंत्री यह बताने की कृपा करेंगे कि :

(क) क्या सरकार ने उत्तर प्रदेश में चल रही जल संसाधन संबंधित परियोजनाओं की जांच करने के लिए गत वर्ष केन्द्रीय जल आयोग ने एक दल भेजा था;

(ख) यदि हां, तो इस संबंध में ब्यौरा क्या है; और

(ग) इस संबंध में सरकार ने क्या कार्यवाही की है ?

शहरी विकास मंत्रालय में राज्य मंत्री और जल संसाधन मंत्रालय में राज्य मंत्री का अतिरिक्त प्रभार (श्री पी. के. थुंगन) : (क) जी नहीं ।

(ख) और (ग) प्रश्न नहीं उठते ।

Slow progress of work of Brahmaputra Board

3238. SHRI TARA CHARAN MAJUMDAR : Will the Minister of WATER RESOURCES be pleased to state :

(a) whether it is a fact that the State Government of Arunachal Pradesh is interfering with the work of the Brahmaputra Board in conducting the surveys in Arunachal Pradesh, which has resulted in slow progress of the work of the Brahmaputra Board; and

(b) if so, what action has been taken by Government so that the work may be completed within shortest time ?

THE MINISTER OF STATE IN THE MINISTRY OF URBAN DEVELOPMENT WITH ADDITIONAL CHARGE OF THE MINISTER OF STATE IN THE MINISTRY OF WATER RESOURCES (SHRI P. K. THUNGON) : (a) and (b) Brahmaputra Board did not get the cooperation of Arunachal Pradesh for conducting surveys in their State. The Centre has requested the Government of Arunachal Pradesh for allowing Brahmaputra Board to undertake the required surveys. Permission from them is awaited.

Shortage of water in Vasant Vihar, Delhi

3239. SHRI O. RAJAGOPAL : Will the Minister of URBAN DEVELOPMENT be pleased to state :

(a) whether it is a fact that about 4 lakh gallons of water per day is required for CGH Complex, Vasant Vihar, New Delhi;

(b) whether it is also a fact that not even half of the required quantity of water is being supplied at present;

(c) if so, the reasons therefor and the quantity of water supplied to the colony during the last six months;

(d) whether it is also a fact that Government assured to meet full requirement of this colony after the completion of Booster Pumping Station at Deer Park; and

(e) if so, the reasons for not supplying required quantity of water to the colony even after the pumping Station has been in operation for quite sometime ?

THE MINISTER OF STATE IN THE MINISTRY OF URBAN DEVELOPMENT WITH ADDITIONAL CHARGE OF THE MINISTER OF STATE IN THE MINISTRY OF WATER RESOURCES (SHRI P. K. THUNGON) : (a) and (b) Yes, Sir.

(c) The Delhi Water Supply & Sewage Disposal Undertaking has reported that at present about 1.5 lakh gallons of water per day is being supplied to the area. This supply is being augmented by C.P.W.D. through 5 number of tubewells to the tune of 80,000 to 90,000 gallons per day. The Delhi Water Supply & Sewage Disposal Undertaking is unable to supply the required water to CGH Complex, Vasant Vihar due to increase in demand of water in South Delhi from Greater Kailash Booster Pumping Station and less availability of water at the booster pumping station 'Deer Park'.

(d) and (e) The Delhi Water Supply & Sewage Disposal Undertaking has reported that the Deer Park Booster Pumping Station was commissioned in October, 1989. Water Received at Deer Park Booster Pumping Station is about 7 MGD. against the projected availability of 16 MGD. This is due to the increase in the demand of South